



January 17, 2012

SFA SANIFLO INC.
JOHAN BOUWER
105 NEWFIELD AVE SUITE A
EDISON NJ 08837

Re: Description: MACERATING PUMP, ALTERNATE PLUMBING SYSTEM
Manufacturer: SFA SANIFLO INC.
Product Name: SANIBEST AND SANIPLUS
Model Number(s): NONE
Product File No: 20060296

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 82.30(10) (b) 3.a. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The venting system of the connecting fixtures must conform to requirements of SPS 382.31 of the Wisconsin Administrative code
- The discharge pipe must connect to a sanitary drain system in accordance with SPS 382.30 (10) of the Wisconsin Administrative code.
- The venting system serving the macerating unit must conform to requirements of SPS 382.31 of the Wisconsin Administrative code, "vents for sumps".
- The Sanibest macerating unit may only accept waste from a lavatory and/or a bathtub with or without a shower. It MAY NOT accept waste from a shower unit.

This approval supersedes the approval issued on April 15, 2008 under product file number 20060296.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060296.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov